

Innovative. Efficient. Dependable. Dunkirk.



## Dunkirk Excelsior Oil-Fired High Efficiency 3-Pass Hot Water Boiler

Dimensions/Weights		Model	No. of Sec.	Boiler Input Rate (MBH) <sup>(1)</sup>	Heating Capacity (MBH) <sup>(1) (2)</sup>	Net AHRI Rating, Water (MBH) (1) (3)	Chimney Size	Boiler Flue	Firing Rate GPH <sup>(4)</sup>	AFUE %		
		3 NS.	EXB4075*	4	105	92	80	8" x 8" x 15'	5" (13 cm)	0.75	87.0	
İ			EXB4095	4	133	114	99	8" x 8" x 15'	5" (13 cm)	0.95	85.0	
	DIM 'B'		EXB4110	4	154	132	115	8" x 8" x 15'	5" (13 cm)	1.10	84.0	
	(F)		EXB5100*	5	140	123	107	8" x 8" x 15'	5" (13 cm)	1.00	87.0	
			EXB5115	5	161	139	121	8" x 8" x 15'	5" (13 cm)	1.15	85.0	
			EXB5135	5	189	161	140	8" x 8" x 15'	5" (13 cm)	1.35	84.0	
	_		EXB6130*	6	182	160	139	8" x 8" x 15'	5" (13 cm)	1.30	87.0	
	•		EXB6145	6	203	176	153	8" x 8" x 15'	5" (13 cm)	1.45	85.0	
			EXB6165	6	231	198	172	8" x 8" x 15'	5" (13 cm)	1.65	84.0	
31, 31,			EXB7165*	7	231	202	176	8" x 8" x 15'	6" (15 cm)	1.65	87.0	
			EXB7180	7	252	217	189	8" x 8" x 15'	6" (15 cm)	1.80	85.0	
			EXB7190	7	266	228	198	8" x 8" x 20'	6" (15 cm)	1.90	84.0	
			*Energy Star Certifie	ed model								
3/4' NPT DRAIN	T FOR VALVE		(1) 1000 Btu/hr (British Thermal Units Per Hour)									
	FRONT		(2) Heating Capacity and AFUE based on 13.1% CO2 (13.5% CO2 at 0.95 GPH and 1.10 GPH, 13.2% CO2 on 7165 model), -0.02" w.c. draft in breech, and # 1 smoke or less. Testing is done in accordance with U.S. DOE (Department of Energy) test procedure.									
NPTSUPPLY	pe of		(3) Net AHRI ratings shown are based on piping and pickup factor of 15% in accordance with AHRI Standard as published by Hydronics Institute.  Contact Technical Support before selecting boiler for installations having unusual piping and pickup requirements, such as intermittent system operation, extensive piping systems, etc.									
		7	(4) Gallons per hour.									
	1		General Information (See Installation, Operation and Maintenance Manual for complete instructions)									
3/4'-	v- -					Combustible Materials (Required) <sup>(6)</sup>	Accessibility, Cleaning, & Servicing (7)					
			Clearances			· · · · ·	04" (61 cm)					
	70te W 157		(6) Required distances measured from boiler jacket or	Top Right Side		12" (32 cm)		24" (61 cm)				
SIDE						2" (5 cm)	24" (61 cm)					
			flue.	Left Side		2" (5 cm)	24" (61 cm)					
		<b>1</b>	(7) Accessibility, Cleaning &	Floor		Combustible	No Requirement					
			Servicing recommendation.	Front		17" (43 cm)	24" (61 cm)					
			recommendation.	Back		See Flue	18" (46 cm)					
				Flue								
				Flue	<u></u>	9" (23 cm)		9	(23 CIII)			
42 1/2"		)	Connections Return/Supply Water 1-1/4" NPT									
PLUC CHAPT TO SET UP. 1 1/4* WIFT TO SET UP.			Electrical		120 Volts AC, 60 hertz, 1 phase, Less than 12 amps (15 amp circuit recommended)							
			Water Content	t	EXB4 - 3.6 Gallons, EXB5 - 4.3 Gallons, EXB6 - 5.1 Gallons, EXB7 - 5.9 Gallons							
			Standard Equipment		Boiler Control Module: Hydrolevel Fuel Smart HydroStat Control - combination Low Water Cut Off with boiler temperature reset and circulator control. User Display Interface: Digital display with easy to set dial-type limit settings. Heat Exchanger: High efficiency, cast iron, 3-pass design with reversible swing door and target wall. Efficiency baffles/liner by model. Combustion: Oil burner with protective cover, flexible oil line. Electrical: Wiring harness with Molex connectors. Burner electrical disconnect. Other: Temperature/pressure guage, 3/4" ASME relief valve, drain valve, textured painted steel jacket.							
Models	Dim. "A"	Ship	<del></del>									
wouels		Wgt.	Options Beckett or Riello Burner, Manual Reset High Limit with plug-in Molex connect						ector, and [	Direct Vent.		
EXB4	18 3/8" 46 cm	436 lbs. (197.8 kg)	Certifications									
EXB5	21 5/8" 56 cm	496 lbs. (225.0 kg)										
EXB6	24 7/8" 64 cm	560 lbs. (254.0 kg)			-Energy S	(9)	7 ®	S <sub>ME</sub>		CERTIF	FIED®	
EVB7	28 1/8"	620 lbs.	1		LEARN MORE AT energystar.gov		الع كر			www.ahridirec	tory.org	
EXB7	72 cm	(281.2 kg)			3,	0	00	Н				

All ratings and specifications subject to change.

PN 240007379 Rev. 9/15



Contractor







